



Telephone:0484-2926286
email:-qcsdlmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB,NETTOOR -682040
WATER TEST REPORT

Report No:NTR/1407/06/24

Report Issue Date: 04.06.2024

Customer Name &Address	Date of Receipt of Payment	03.06.2024
PRABHATH PUBLIC SCHOOL SENIOR SECONDARY UDAYAMPEROOR 682307	Date of Sample received	03.06.2024
	Sample given by	Customer
	Sample Code	NTR/1407/06/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	FILTER WATER FOR DRINKING PURPOSE
	Sample Quantity	2 L.
	Test performing dates : From:03.06.24 to 04.06.2024	

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.48
2	pH @ 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	7.20
3	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	8.81
4	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	37.62
5	Nitrate (as NO3)	mg/L	APHA 23rd Edition(UV Screening Method) 2017	45	3.21
6	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	0.06
7	Electrical conductivity at 25°C	µS/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	--	101.70

Remarks:-


- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4)BDL-Below Detection Limit
- 5)DL-Detectable Limit

Analysed By

ATHULYA

Reviewed & Authorized By

ASHLY JOSE



QUALITY MANAGER
QCSDL NETTOOR

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Rev No:09	Rev. Date : 29.04.2024	Page 1 of 1



Telephone:0484-2926286
email:-qcsdlmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, NETTOOR -682040
WATER TEST-BACTERIOLOGY REPORT

Report No:NTR/1407/06/24

Report Issue Date: 04.06.2024

Customer Name & Address		Date of Receipt of Payment	03.06.2024	
PRABHATH PUBLIC SCHOOL SENIOR SECONDARY UDAYAMPEROOR 682307		Date of Sample received	03.06.2024	
		Sample given by	Customer	
		Sample Code	NTR/1407/06/24	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	FILTER WATER FOR DRINKING PURPOSE	
		Sample Quantity	250 ML	
		Test performing dates :		From:03.06.24 to 04.06.2024
Sl. No.	Source	Acceptable Limit as per IS 10500-2012	Test Method	RESULT
1	Total Coliform	Shall not be detected/100ml	IS15185-2016	ABSENT
2	E Coli	Shall not be detected/100ml	IS15185-2016	ABSENT

Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed & Analysed By

Bacteriologist

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Rev No:09	Rev. Date :29.04.2024	Page 1 of 1

