

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 230/24

Dated: 11.6.2024

It is certified that an inspection team headed by Raphy Joseph

(Name of Officers with designation) from F.H.C. Udayamperoor PHED

inspected the PRABHATH PUBLIC SCHOOL; PRMC In; UDAYAMPEROOR

(Name & Address of the school) on 11.6.2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. NTR/1407/06/24 dated 01.06.2024

KWA of QUALITY CONTROL SUB DISTRICT LAB NETOOR (PHED Lab) certified that

the PRABHATH PUBLIC SCHOOL; UDAYAMPEROOR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 2024 - 2025



Signature with Seal: Raphy Joseph

Name: Raphy Joseph

Designation: HEALTH INSPECTOR

Name & Address of the Office / Department: FAMILY HEALTH CENTRE

UDAYAMPEROOR

To
THE PRINCIPAL
PRABHATH PUBLIC SCHOOL; UDAYAMPEROOR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Telephone:0484-2926286
email:-qcsdlmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB,NETTOOR -682040
WATER TEST REPORT

Report No:NTR/1407/06/24

Report Issue Date: 04.06.2024

Report No:NTR/1407/06/24			Report Issue Date: 04.06.2024		
Customer Name & Address PRABHATH PUBLIC SCHOOL SENIOR SECONDARY UDAYAMPEROOR 682307			Date of Receipt of Payment	03.06.2024	
			Date of Sample received	03.06.2024	
			Sample given by	Customer	
			Sample Code	NTR/1407/06/24	
			Sample Name	Drinking Water	
			Sample Condition	Good	
			Source of Sample	FILTER WATER FOR DRINKING PURPOSE	
			Sample Quantity	2 L	
			Test performing dates :		
Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.48
2	pH @ 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	7.20
3	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	8.81
4	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	37.62
5	Nitrate (as NO3)	mg/L	APHA 23rd Edition(UV Screening Method) 2017	45	3.21
6	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	0.06
7	Electrical conductivity at 25°C	µS/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	--	101.70

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4)BDL-Below Detection Limit
- 5)DL-Detectable Limit

Analysed By

ATHULYA

Reviewed & Authorized By

ASHLY JOSE

End of Report

Issue Date: 22.09.21

Rev. Date :29.04.2024

QUALITY MANAGER
QCSDL NETTOOR

KWA/QCSDL/NTR/F-21

Rev No:09

Page 1 of 1



Telephone:0484-2926286
email:-qcsdlmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB,NETTOOR -682040
WATER TEST-BACTERIOLOGY REPORT

Report No:NTR/1407/06/24

Report Issue Date: 04.06.2024

Report Issue Date: 03.06.2024

Customer Name & Address		Date of Receipt of Payment	03.06.2024	
PRABHATH PUBLIC SCHOOL SENIOR SECONDARY UDAYAMPEROOR 682307		Date of Sample received	03.06.2024	
		Sample given by	Customer	
		Sample Code	NTR/1407/06/24	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	FILTER WATER FOR DRINKING PURPOSE	
		Sample Quantity	250 ML	
		Test performing dates : From:03.06.24 to 04.06.2024		
Sl. No.	Source	Acceptable Limit as per IS 10500-2012	Test Method	RESULT
1	Total Coliform	Shall not be detected/100ml	IS15185-2016	ABSENT
2	E Coli	Shall not be detected/100ml	IS15185-2016	ABSENT

Remarks:-

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed & Analysed By

Bacteriologist

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Rev No:09	Rev Date :29.04.2024	Page 1 of 1

